



**NOTES:**

1. REINFORCEMENT STEEL TO BE MINIMUM 1 METRE LENGTH N12 WITH 100 CENTRES.
2. MINIMUM OF 200mm PATH EITHER SIDE OF THE MANHOLE.
3. CONCRETE COVER TO REINFORCEMENT STEEL TO BE MINIMUM 50mm.
4. INCREASE THICKNESS OF FOOTPATH PANEL FOR 1 METRE EITHER SIDE OF MANHOLE TO 150mm.
5. ALL MEASUREMENTS ARE IN MILLIMETRES UNLESS NOTED OTHERWISE.



**shire of  
kalamunda**

DEPARTMENT  
OF  
ENGINEERING SERVICES

TITLE:

**MANHOLE/FOOTPATH DETAIL**

DRN: **G LAWRENCE**

DATE: **01/12/2006**

AUTHORISED:

SCALE: **1:25**

INIT:

DATE:

DWG NO:

**10/30**